

REC/CO/RE-DDUGJY/12Plan/2015/ 10958

Dated: 13.11.2015

To  
CMDs/MDs/Chief Engineers/HoDs  
(CPSUs/SEBs/DISCOMs/Power Departments)  
PIAs for RE-DDUGJY XII Plan & DDUGJY Projects

**Sub: Amendment in Technical Specification of Piercing Connector.**


Sir/Madam,

This has reference to the technical specification of Piercing Connector to be used in RE-DDUGJY (erstwhile RGGVY) XII Plan & DDUGJY Schemes. The Clause no. 5.1.3.8 of specification has been amended which is as hereunder:

Existing Provision in the Clause	Amended Clause
“the contact plates of piercing connector should be made of tinned copper”	“the contact plates of piercing connector should be made of tinned copper/aluminum alloy”

This is for information and further needful action please.

Yours sincerely,



(G. S. BHATI)

General Manager (DDUGJY/QA)

**Copy to:**

ZM/CPM- Please circulate to PIAs in the states of your purview.